§111.30-24 Generation systems greater than 3000 kw.

Except on a non-self-propelled mobile offshore drilling unit (MODU) and a non-self-propelled floating Outer Continental Shelf facility, when the total installed electric power of the ship's service generation system is more than 3000 kW, the switchboard must have the following:

- (a) At least two sections of the main bus that are connected by:
 - (1) A non-automatic circuit breaker;
 - (2) A disconnect switch; or
 - (3) Removable links.
- (b) As far as practicable, the connection of generators and duplicated equipment equalized between the sections of the main bus.

[CGD 74–125A, 47 FR 15236, Apr. 8, 1982, as amended by CGD 94–108, 61 FR 28279, June 4, 1996]

§ 111.30-25 Alternating-current ship's service switchboards.

- (a) Except as allowed in paragraph (g) of this section, each alternating-current ship's service switchboard must have the equipment required by paragraphs (b) through (f) of this section.
- (b) For each connected generator, each switchboard must have the following:
- (1) A circuit breaker that meets §111.12-11 and §111.50-5.
- (2) A disconnect switch or link for each generator conductor, except a switchboard having a draw-out or plugin type generator circuit breaker that disconnects:
 - (i) Each generator conductor; or
- (ii) If there is a switch in the generator neutral, each ungrounded conductor.
- (3) A pilot lamp connected between the generator and the circuit breaker.
- (4) An ammeter with a selector switch that connects the ammeter to show the current in each phase.
- (5) A voltmeter with a selector switch that connects the voltmeter to show the:
- (i) Generator voltage of each phase; and
 - (ii) Bus voltage of one phase.
- (6) A voltage regulator and voltage regulator functional cut-out switch.
- (c) For each generator that is not excited from a variable voltage or rotary

amplifier that is controlled by a voltage regulator unit acting on the exciter field, each switchboard must have:

- (1) A generator field rheostat:
- (2) A double-pole field switch;
- (3) Discharge clips; and
- (4) A discharge resistor.
- (d) If generators are arranged for parallel operation, each switchboard must have:
- (1) A speed control for the prime mover of each generator;
- (2) An indicating wattmeter for each generator; and
- (3) A synchroscope and synchronizing lamp that have a selector switch to show synchronization for paralleling generators.
- (e) Each switchboard must have the following:
- (1) Ground detection that meets Subpart 111.05 for the:
 - (i) Ship's service power system;
 - (ii) Normal lighting system; and
 - (iii) Emergency lighting system.
- (2) A frequency meter with a selector switch to connect the meter to each generator.
 - (3) An exciter field rheostat.
- (f) For each shore power connection each switchboard must have:
 - (1) A circuit breaker or fused switch;
- (2) A pilot light connected to the shore side of the circuit breaker or fused switch; and
- (3) One of the voltmeters under paragraph (b)(5) of this section connected to show the voltage of each phase of the shore power connection.
- (g) The equipment under paragraphs (b), (d), (e), and (f) of this section, except the equipment under paragraphs (b)(1), (b)(2), and (f)(1), must be on the ship's service switchboard or on a central control console that:
- (1) Is in the same control area as the main ship's service switchboard or can remotely control the ship's service generator circuit breaker;
- (2) Has a generator section that has only generator functions;
- (3) Has the generator section segregated from each other console section by a fire-resistant barrier; and
- (4) Has cabling from the main switchboard to the generator section of the console that: